

Heisener.com

# P51-1500-S-P-M12-4.5V-000-000

### P51-1500-S-P-M12-4.5V-000-000 Information

Part Number P51-1500-S-P-M12-4.5V-000-000

Manufacturer SSI Technologies Inc Sensors, Transducers Category

Pressure Sensors, Transducers

**Description** SENSOR 1500PSI M20-1.5 6G 4.5V

**Package** 

For the pricing/inventory/lead time, please contact

Website: https://www.heisener.com For Reference Only

E-mail: salesdept@heisener.com



Request a Quote

## **Certified Quality**

Heisener's commitment to quality has shaped our processes for sourcing, testing, shipping, and every step in between. This foundation underlies each component we sell.









# P51-1500-S-P-M12-4.5V-000-000 Specifications

Manufacturer Part Number	P51-1500-S-P-M12-4.5V-000-000
Manufacturer	SSI Technologies Inc
Category	Sensors, Transducers
	Pressure Sensors, Transducers
Package	Cylinder
Series	MediaSensor?
Pressure Type	Sealed Gauge
Operating Pressure	1500 PSI (10342.14 kPa)
Output Type	Analog Voltage
Output	0.5 V ~ 4.5 V
Accuracy	±0.5%
Voltage - Supply	5V
Port Size	Male - M20 x 1.5
Port Style	Threaded
Features	Amplified Output, Temperature Compensated
Termination Style	M12, 4 Pin
Maximum Pressure	-
Operating Temperature	-40°C ~ 105°C
Package / Case	Cylinder
Supplier Device Package	-
	Report errors?

#### P51-1500-S-P-M12-4.5V-000-000 Guarantees



#### **Ouality Guarantees**

We provide 90 days warranty. \*

If the items you received were not in perfect quality, we would be responsible for your refund or replacement, but the items must be returned in their original condition.



#### **Service Guarantees**

We guarantee 100% customer satisfaction.

Our experienced sales team and tech support team back our services to satisfy all our customers.

### P51-1500-S-P-M12-4.5V-000-000 Payment Methods



















## P51-1500-S-P-M12-4.5V-000-000 Shipping Methods













If you have any question about P51-1500-S-P-M12-4.5V-000-000, please do not hesitate to contact us!

Website: https://www.heisener.com E-mail: salesdept@heisener.com